

Avlite[®]
www.avlite.com



AV-OL-KT-E1
Obstruction Lighting Kit
FAA - E-1

INSTALLATION & SERVICE MANUAL

V1.1



Version No.	Description	Date	Reviewed	Approved	Design
1.0	AV-OL-KT-E1 Manual Launch	June 2019	P. Naidu	W. Evans	M. Sugars
1.1	Data update	January 2020	P. Naidu	W. Evans	M. Sugars
1.2	Data update	July 2020	P. Naidu	W. Evans	M. Sugars

Table of Contents

1.0	Introduction	4
2.0	Technology	5
3.0	AV-OL-KT-E1 Models	6
3.1	Available Options	9
4.0	AV-OL-KT-E1 Data Sheet	10
5.0	Safety Information	11
6.0	Operation and Setup	12
6.1	System Overview	12
6.1.1	AV-OL-CMI	12
6.1.2	L-810(F)	13
6.1.3	T3 Controller	15
6.1.4	Interface Wiring	16
6.1.5	GPS Synchronisation	17
7.0	Unpacking, Installation, Wiring and Setup	18
7.1	Unpacking	18
7.2	Installation	19
7.2.1	Tools Required	19
7.2.2	Additional Tools Required	20
7.2.3	Cabling Requirements	20
7.2.4	Factory Settings	20
7.2.5	Installation Recommendation	20
7.3	Testing Procedure	37
8.0	Maintenance and Servicing	38
9.0	Replacement Parts	38
10.0	Troubleshooting	39



1.0 Introduction

Congratulations! By choosing to purchase an Avlite product, you have become the owner of one of the most advanced obstruction products in the world.

Avlite Systems draws on more than 25 years of experience in the design and manufacture of navigation aids, and particular care has been taken to ensure your product gives years of trouble-free service.

As a commitment to producing the highest quality products for our customers, Avlite has been independently certified as complying with the requirements of ISO 9001:2015 quality management system.

By taking a few moments to browse through this booklet, you will become familiar with the versatility of your lighting kit, and be able to maximise its operating function.

Please remember to complete the Avlite warranty registration card accompanying your product.

Acronyms and Abbreviations

The following abbreviations will be used throughout this Installation Manual:

cd	candela
ft.	foot
in.	inch
LED	Light Emitting Diode
VAC	Volts, Alternating Current
VDC	Volts, Direct Current
AWG	American Wire Gauge
CMI	Combined Medium Intensity

2.0 Technology

Avlite Systems is a world-class solar lighting systems manufacturer with a proven reputation for rapid, innovative, and agile technology solutions designed specifically for defence, government, civil and humanitarian aid operations in the most remote, toughest environments.

Electronics

Avlite employs leading in-house electronic engineers in the design and development of software and related circuitry. All individual electronic components are sourced directly by Avlite procurement staff ensuring that only the highest quality components are used in our products.

LED Technology

All Avlite lights use the latest advancements in LED (Light Emitting Diode) technology as a light source. The major advantage of LED's over traditional light sources is well established in that they typically have an operational life in excess of 100,000 hours, resulting in substantial savings to maintenance and servicing costs.

Precision Construction

Commitment to investing in the design and construction of injection-moulded parts including optic lenses, light bases and a range of other components ensures that all Avlite products are of a consistent and superior quality.

Optical Performance

Avlite manufactures a range of aviation LED lenses moulded from multi-cavity dies. The company has superior in-house lens manufacturing capabilities to support outstanding optical performance.

Award-winning, Patented Technology

Several United States and Australian patent registrations are held on Avlite's range of innovative designs, with other regional patents pending in Canada, United Kingdom and Europe.



3.0 AV-OL-KT-E1

The AV-OL-KT-E1 Obstruction Lighting Kit is a full turnkey solution for E1 defined structures ranging between 201 and 350 feet (61-106 meters) above ground level (AGL). These include telecommunication towers and utility towers, wind turbines, cranes, buildings and other tall structures.

The E-1 Obstruction Solution comes fully assembled, ready to install, and includes the following items:

- 1 x L-864/865 Combined Medium Intensity Obstruction Light (CMI),
- 3 x L-810(F) obstruction lights
- All necessary junction boxes
- Central Control Unit
- External Photocell

The top light (CMI) remains ON 24 hours a day, illuminated white for daytime operation and red for night operation, while the mid lights (L-810(F)) are illuminated at night only with GPS flash synchronization with the top light.

The E-1 Obstruction Solution is available in two input power configurations, a universal AC (90-264VAC) or 48 VDC (solar compatible) and comes with Star2M monitoring via GSM or SATCOM as options

The best in class system power draw allows tower owners to utilize solar for locations lacking reliable and/or cost-effective access to regular utility power. Avlite's experience, knowledge and tools for solar applications provides years of maintenance free, off-grid operation with an emphasis on FAA compliance.


With a range of accessories including brackets, cable and junction boxes, utility and telecommunication companies, electrical contractors and state and local governments can now quickly and easily purchase all obstruction lighting components from a single source, simplifying the ordering process and reducing the possibility of incompatible, stand-alone components from different manufacturers.

Note: This installation and service manual must be used in conjunction with the installation manuals of the individual components.


- AV-OL-CMI Installation and Service Manual
- AV-OL-L810(F) Installation and Service Manual



1 x L-864/865 CMI fixture




3 x L-810(F) fixtures



1 x Control Unit



Note: Mounting hardware not included.







1 x Top Level Junction Box

Note: Mounting hardware not included.



1 x Mid Level Junction Box

Note: Mounting hardware not included.



3.1 Available Options

- Solar Input Power (for 48VDC) – Call Avlite for details.
- Cable Kit (suitable for 350 ft. structure) Includes:
 - 375' of 18 AWG, 3 conductor wire
 - 375' of 10 AWG, 2 conductor wire
 - 325' of 18 AWG, 5 conductor wire
- Light Mounting Brackets (each)
 - For L864/865 Right Angle Pole Mounting Bracket-Medium Intensity Fixtures
 - For L-810(F): Right Angle Mounting Bracket-Low Intensity Fixtures
- Remote Monitoring and Control
 - Avlite offers remote Star2M monitoring via GSM or SATCOM.
 - Operators can remotely monitor the status of their installation from a compatible device. The system can also be configured to send out SMS text messages or e-mail alerts to designated operators should alarm conditions be triggered, such as low voltage or light failure.
 - Please contact Avlite for operational information for the Monitoring & Control options. Visit <https://www.star2m.com> to find out more about Star2M
- Mounting Bolt Kit (includes bolts, nuts, washers)
 - Please contact Avlite for further details
- Control Unit Mounting Hardware
 - 2" pipe clamps
 - ¾" pipe clamps

Please contact Avlite for further details.



4.0 AV-OL-KT-E1 Data Sheet

FAA E-1 Obstruction Kit	AC	DC		
Electrical Characteristics				
Input Voltage	90-264VAC	48VDC		
Input Frequency	50/60 Hz	N/A		
Power Consumption				
Peak	555VA	490W		
Average	Day: 34VA Night: 5.1VA	Day: 30W Night: 4.5W		
Physical Characteristics				
Dimensions	Height (inches/mm)	Width (inches/mm)	Length (inches/mm)	Mass (lbs./kg)
AV-OL-CMI (L-864/ L-865)	8.25 / 209	11.75 / 296	6.75 / 171	21.5 / 9.7
L-810(F)	5.4 / 137	4.75 / 121	3.875 / 100	0.375 / 0.4
Control Unit	24 / 610	20.5 / 505	9.5 / 241	63 / 28.5
Top Junction Box	4.86 / 123	8.68 / 221	7.74 / 197	7.05 / 3.2
Middle Junction Box	4.78 / 121	10.32 / 262	11.77 / 299	9.92 / 4.5
Mounting				
AV-OL-CMI (L-864, L-865)	200mm bolt pattern			
AV-OL-L-810(F)	¾ inch pipe thread			
Control Unit	Wall mounted (mounting accessories available)			
Top Junction Box	Mounting accessories available			
Middle Junction Box	Mounting accessories available			
Certifications and Compliance				
CE	EN61000-6-3:2007, EN61000-6-1:2007			
Quality Assurance	ISO9001:2015			
Protection Rating	Junction and Control Box: IP65/NEMA4X		Lights: IP67	
FAA	L-810(F), L-864, L-865, Medium Intensity Obstruction Light, FAA AC 150/5345-43H			
Transport Canada	CL-864, CL-865 Canadian Aviation Regulations 2015-2, Standard 621 - Obstruction Marking and Lighting, March 2016 Appendix B			
DGAC	L-810(F) Low Intensity Obstruction Light (Qualified by Intertek)			
Intellectual Property				
Trademarks	AVLITE® is a registered trademark of Avlite Systems			
Warranty *	5 year warranty on light fixtures 3 year warranty on Control Unit and Junction Boxes			
Options Available	<ul style="list-style-type: none"> · Cable Kit suitable for 350' structures · Mounting Brackets for L-864/865 and L-810(F) 			

*Please refer to the individual light installation manuals for further specifications

5.0 Safety Information

Before proceeding with installation or service, make sure the following conditions are met:

- Ensure the tower or mast is grounded (NO RF OR SHOCK HAZARD)
- Check the mast lighting circuit is not faulty
- Ensure power lines are not 'live' (NO ELECTRICAL HAZARD)
- Avoid touching live circuits!
- Avoid touching any component or any part of the circuitry while the unit is operating. Do not change components or make adjustments inside the unit with power on.
- Make sure the light fixture mounting is vertically aligned to guarantee the required beam pattern of the obstruction light.
- Make sure any nearby obstacles do not impede the lights' beam pattern.
- When installing, comply with all local electrical code(s).
- Mains power should always be disconnected when work is being done in close proximity to electrical fittings, and electrical work should only be done by a licensed electrician.
- Operate the light only within the indicated electrical ratings and product usage instructions.
- To ensure that the light and peripheral equipment function safely and correctly, use cable in compliance with the effective local electrical code.
- Do not stare at the LED or shine the LED into your eyes or those of another person.
- Dispose of the product according to the local laws and regulations for your region, for example, at a recycling centre that accepts electronic devices.



6.0 Operation and Setup

Avlite's E1 Obstruction Lighting Solution Kit consists of five components: A Control Unit which provides power, day & night control and (optional) remote monitoring, a single L-864/865 RED/WHITE omnidirectional, Combined Medium Intensity obstruction beacon (CMI), and three L-810(F) red obstruction lights.

Both the CMI and L-810(F) incorporate internal diagnostic checking and an alarm contact for remote monitoring. The alarm relay is energized in normal operation and is released if there is an LED or power fault.


An External Photocell allows the lights to automatically switch between day and night mode. In night mode, all lights flash in synchronization with one another via integrated GPS synchronisation, per the guidelines in the FAA 7460-1L Advisory Circular for lighting E1 structures. In day mode, the CMI is illuminated white with the L-810(F) lights off. The Photocell output can also be overridden for system testing and maintenance via the Photocell Bypass Switch. (See section 6.1.3 for more information).

The Control Unit automatically evaluates the E-1 system for operation and performance criteria while providing local and remote display of information and alarms; operators can conveniently view the lights' real time status from the web based Star2M™ portal (if option purchased).

6.1 System Overview

6.1.1 AV-OL-CMI

External




Power	
Positive (+VDC)	Black
Negative (-VDC)	White

Data	
Ground Ref (GNDA)	White
PC Input (IN1)	Black
Alarm Common (COM)	Red
Alarm Signal (NC)	Green

Lantern Status

The CMI is fitted with one red and one yellow status LED and provides the operator with an indication of the lantern status.



The LEDs are located on the side of the lantern.

The red status LED is used to indicate the health of the lanterns' power system. The yellow status LED is used to indicate the operational status of the lantern. These indicator LED's can be viewed at the base of the lens.

RED			
Status LED	Lantern Status	Lantern	Condition
Steady	Flat Battery cut off is in effect	OFF	Battery voltage is less than 43.0V
Slow	High Voltage	ON	Battery voltage is above 54.0V
Off	Optimal Voltage	ON	Battery Voltage is between 50.0V – 54.0V
1 Quick	OK Voltage	ON	Battery Voltage is between 48.0V – 50.0V
2 Quick	Low Voltage	ON	Battery Voltage is between 47.0V – 48.0V
3 Quick	Poor Voltage	ON	Battery Voltage is between 43.0V – 47.0V
4 Quick	Flat Voltage	ON	Battery voltage is less than 43.0V

Once the Flat Battery cut-off condition is in effect, the lantern will not turn back on until it sees day light and the battery voltage is above the "OK" threshold for at least one minute.




YELLOW			
Status LED	Lantern Status	Lantern	Condition
Off	Standby	OFF	Lantern is in Standby Mode
Quick Flashing 0.15s on, 0.15s off	Day To Night Transitioning (Dusk Till Dawn Mode)	OFF	Light is activating and will turn on after detecting 30 seconds of continuous darkness
2 Quick Flashes every 2s	Operational, Not Synchronized	ON	Lantern is in Normal operating condition. It is not connected to any GPS synchronization
1 Quick Flashes every 2s	Operational, Sync in Progress	ON	Lantern is 're-syncing' with GPS. The lantern re-syncs with the GPS every 15 minutes
Slow Flashing 1.5s on, 1.5s off	Operational, Synchronized	ON	Normal operating condition. Lantern is synchronized to GPS-enabled lanterns
2 Quick flashes every 11s	Operational, Synchronized as Slave	ON	Lantern is a Hard Wire Synchronization Slave

If the lantern is not fitted with the GPS Synchronization option, then the following conditions are not possible: 1 Quick Flash, and Slow Flashing.

For more information regarding the CMI, please consult the relevant sections of the corresponding service and installation manual.

6.1.2 L-810(F)

External



Power and Data	
Positive (+VDC)	Red
Negative (-VDC)	Black
IN1	White
COM	Orange
NO	Green

LED Fault

In the event of a singular LED fault, either open circuit or closed circuit across the LED, the light unit will turn off all LED's and actuate the Fault Relay.

For more information regarding the L-810(F), please consult the relevant sections of the corresponding service and installation manual.

6.1.3 T3 Controller

The T3 Control Unit is an essential component of the E1 Obstruction Lighting Kit as it provides power, control and monitoring of the light fixtures in the system.

For safety and security, the control enclosure comes with a safety interlock which prevents access to the controller while the system is powered on.

The Controller is available in two input power configurations; a universal AC or DC and comes with remote monitoring via Star2M with either GSM or Satcom telemetry types as options.

By default, the control unit comes with 2 dry contacts for external monitoring of both the CMI and L-810(F) light fixtures which receive the associated alarm (i.e. Group 2 for the CMI and Group 1 for the L-810(F) lights) in the event of a power or LED fault. (Note: External dry contact monitoring is unavailable if remote monitoring via GSM or Satcom has been enabled)

A Photocell Bypass Switch is provided with the Control Unit to override the Photocell output for system testing and maintenance. It is factory-set to AUTO (auto day/night) mode.

To test the function of lights for **day** operation, turn the Photocell Bypass Switch to the **Day** position. The CMI should be illuminated white with the L-810(F) light fixtures off.

To test the function of lights for **night** operation, turn the Photocell Bypass Switch to the **Night** position. The CMI and all L-810(F) lights should be illuminated red and flash in synchronisation.


To return to the **Auto** mode, return the switch to the **Auto** position.

Note: Time delays are to be expected when changing modes. Allow up to 1 minute to change between functions.





6.1.4 Interface Wiring



6.1.5 GPS Synchronization

Avlite has utilized the latest advancements in GPS technology to develop an internal synchronization system that is incorporated into the lights. Using overhead satellites, multiple obstruction lights set to the same flash pattern will flash in unison. No additional power supplies, aeriels or control systems are required, and with its microprocessor-based system, the GPS option is specifically designed to provide maximum reliability and performance over a wide range of environmental conditions.

Operating Principle

Each light operates independently and requires no operator intervention. A minimum of 4 satellites need to be in view for the built-in GPS receiver to collect time data. At dusk, the light sensor will turn the light on. If time data is available, the light will come on synchronized to every other light with the same selected flash code. Synchronization is achieved using an internal algorithm based on the highly accurate time base and time data received from the satellites. The satellite data is provided from a number of earth stations using atomic clocks as the time base. Continuous self-checking ensures that the light will continue to run in synchronization.

Light Activation

At power-up the microprocessor checks that the internal GPS module is programmed correctly and is able to provide valid time base and time data. Once outside with a clear view of the sky, valid data should become available within 20 minutes.

Note: Lights will not synchronize if different flash codes are selected.



7.0 Unpacking, Installation, Wiring and Setup

7.1 Unpacking

Unpack all hardware and inspect for damage. If there is any damage, please contact your Avlite Office.

Retain original packing material for possible future use in shipping.

7.2 Installation



WARNING:

Confirm that the power switch is toggled to the OFF position when power is connected. **DO NOT** connect power to the PCU when the control panel power switch is toggled to the PWR position. This may result in damage to the power sources.



WARNING:

DO NOT connect directly to the DC output of a generator, or any other unregulated power source. Connecting to an unregulated source may result in damage.



WARNING:

Do not stare into light emitting diode (LED) beams.



CAUTION:

LED lights contain glass components. **Do Not Drop.**

Always follow the instructions outlined in the product manual when cleaning the equipment. Improper cleaning methods and use of unauthorized cleaning agents can damage equipment.

7.2.1 Tools Required

Tools Needed (not supplied)
Flush Cutter
Tongue & Groove Pliers
Silicone Sealant
Cable Jacket Trimmer (optional)
Utility Knife
Electrical Tape
Insulated Terminal Crimper
Wire Strippers 10AWG to 18AWG Range
2.5mm Hex Key
2.0mm Flat Blade Precision Screwdriver
#2 Phillips Screwdriver
Junction Boxes (2) (owner supplied or optional purchase)
Light Mounting Brackets (4) (optional purchase)
Cables (owner supplied or optional purchase)

7.2.2 Location

Refer to FAA AC 150/5345-43 and FAA AC 70/7460-1L for site requirements for obstruction lights.



7.2.3 Cabling Requirements

The installation of the AV-OL-KT-E1 Obstruction Lighting Kit requires the following cables (if optional cable kit is not purchased):

Reference Point	Cable
CMI -Top Junction Box	<ul style="list-style-type: none">• Power Cable: 10 AWG 2 Conductor.• Data Cable: 18 AWG 4 Conductor.
Top Junction Box - Control Unit	<ul style="list-style-type: none">• Power Cable: 10 AWG 2 Conductor.• Data Cable: 18 AWG 3 Conductor.
L-810(F) - Middle Junction Box:	<ul style="list-style-type: none">• Power & Data Cable (x3) = 18 AWG 5 Conductor.
Middle Junction Box- Control Unit	<ul style="list-style-type: none">• Power & Data Cable = 18 AWG 5 Conductor.
Photocell - Control Unit:	<ul style="list-style-type: none">• Power & Data Cable = 18 AWG 3 Conductor.

7.2.4 Factory Configuration

- CMI wired with 10ft flying leads (Power cable and Data cable).
- 1 x L-810(F) wired with 10ft flying lead.
- 2 x L-810(F) wired with 25ft flying lead.
- External Photocell wired with 25ft flying lead.

7.2.5 Installation Recommendation

Note: The sequence of steps can be adjusted for site requirements.

1. Wire and test the system on ground level.

Conduct a basic functional check to ensure that the lights turn on as expected. See section 7.3 *Testing Procedure* for more information.

2. Mount the Control Unit

The Control Unit should be mounted in a reasonable location at eye level to ensure that it is easily accessible for servicing and maintenance. There should be plenty of clearance around all sides to allow direct access when the door of the control unit is completely open.

- a. Attach the required mounting hardware to the top and bottom of the Control Unit.



Example of Control Unit mounting hardware

Pre-installed Control Unit tab

- b. Mount the Control Unit (with the previously attached mounting hardware) to the tower or installation structure using the mounting tabs. Secure using the required mounting fixtures.



Note: Mounting hardware is not included with the kit.



3. Mount External Photocell

Insert the Photocell into the mount (Avlite supplied) by inserting the contact blades into the receptacle. Secure the Photocell assembly to the tower or installation structure using the required mounting fixtures.

The following considerations should be taken into account when mounting the external Photocell:

- Mount in a reasonable location at eye level to ensure that it is easily accessible for servicing and maintenance.
- The Photocell should be pointed away from the equator (North in Northern Hemisphere, South in Southern Hemisphere).
- The Photocell should be located away from bright, artificial lighting.


Note: Mounting fixtures are not supplied.



4. Wire the Photocell to the Control unit and cut cable to the required length.

Wiring instructions-Power and Data Cable:

- Connect the black positive conductor from the External Photocell to the circuit breaker on the 'PC +24VDC' labelled terminal block in the Control Unit
- Connect the white negative conductor from the External Photocell to the 'PC Com' labelled terminal block in the Control Unit
- Connect the green Photocell signal conductor to the 'PC Signal' labelled terminal block in the Control Unit



Refer to section 7.2.3 *Cabling Requirements* for recommended cable sizes.



5. Install the CMI

Mount the L-864/865 Combined Medium Intensity Obstruction light directly to the top of the tower or installation structure either by securing it to the mounting plate or by attaching an optional Avlite Right Angle Pole Mounting Bracket (for medium intensity fixtures) to the tower and bolting the CMI to the bracket.

6. Mount the top junction box.


Note: Mounting hardware for junction boxes is not supplied.

7. Wire CMI to top junction box

- a. Wire CMI power cable to junction box, then wire data cable to junction box.


Wiring instructions-Power Cable:

- Connect the black positive conductor from the CMI to the +48VDC labelled terminal block in the top junction box
- Connect the white negative conductor from the CMI to the -48VDC labelled terminal block in the top junction box



Wiring Instructions-Data Cable:

- Connect the white Ground Ref (GNDA) conductor from the CMI to the GND labelled terminal block in the top junction box
- Connect the red Alarm Common (COM) conductor from the CMI to the COM labelled terminal block in the top junction box
- Connect the green alarm signal (NC) conductor from the CMI to the NC labelled terminal block in the top junction box
- Connect the black Photocell Input (IN1) conductor from the CMI to the PC labelled terminal block in the top junction box
-



- b. Run two cables from the top junction box to the Control Unit, one for power and one for data.


Refer to section 7.2.3 *Cabling Requirements* for recommended cable sizes.




8. Route top junction box to control unit cables

Wiring instructions-Power Cable:

- Connect the black positive conductor from the +48VDC labelled terminal in the top junction box to the 'L-864/865 +24VDC' labelled terminal block in the Control Unit
- Connect the white negative conductor from the -48VDC labelled terminal in the top junction box to the 'L-864/865 -48VDC' labelled terminal block in the Control Unit









Wiring instructions-Data Cable:

- Connect the white Alarm Common (COM) conductor from the top-level junction box to the 'L-864/865 Alarm Com' labelled terminal block in the Control Unit
- Connect the black alarm signal (NC) conductor from the top-level junction box to the 'L-864/865 Alarm Signal' Labelled terminal block in the Control Unit
- Connect the white Photocell Signal (PC) conductor from the top-level junction box to the 'L-864/865 PC Input' labelled terminal block in the Control Unit








9. Mount the L-810(F) lights (x3)

Thread a $\frac{3}{4}$ " pipe thread cord grip to the L-810(F) and attach the light to an owner supplied bracket or optional Avlite Right Angle Mounting Bracket (for low intensity fixtures) with a locking nut.




10. Mount middle junction box

Note: Mounting hardware for junction boxes is not supplied.


11. Wire the L-810(F) lights to the middle junction box.

Wiring instructions-Power and Data cable:

- Connect the red positive conductor from the L-810(F) to the appropriately marked +VDC terminal for marker 1,2,3 or 4 (if installed) in the middle junction box




- Connect the black negative conductor from the L-810(F) to the appropriately marked -VDC terminal for marker 1,2,3 or 4 (if installed) in the middle junction box







- Connect the orange Alarm COM conductor from the L-810(F) to the appropriately marked Alarm COM terminal for marker 1,2,3 or 4 (if installed) in the middle junction box



- Connect the Green NC conductor from the L-810(F) to the appropriately marked Alarm NC terminal for marker 1,2,3 or 4 (if installed) in the middle junction box



- Connect the White PC Input (IN1) conductor from the L-810(F) to the appropriately marked PC terminal for marker 1,2,3 or 4 (if installed) in the middle junction box




Refer to section 7.2.3 Cabling Requirements for recommended cable sizes.




12. Route middle junction box to Control Unit cables

Wiring instructions-Power and Data Cable:

- Connect the red positive CTRL + 24VDC conductor from the middle junction box to the circuit breaker on the 'L-810F +24VDC' labelled terminal block in the Control Unit
- Connect the black negative CTRL + -24VDC conductor from the middle junction box to the 'L-810F -24VDC' labelled terminal block in the Control Unit
- Connect the orange CTRL Alarm COM conductor from the middle junction box to 'L-810F Alarm Com' labelled terminal block in the Control Unit
- Connect the green CTRL Alarm NC Conductor from the middle junction box to the 'L-810F Alarm Signal' labelled terminal block in the Control Unit
- Connect the white CTRL PC (IN1) conductor from the middle junction box to the 'L-810F PC Input' labelled terminal block in the Control Unit





Refer to section 7.2.3 Cabling Requirements for recommended cable sizes.

DC Installation:

Connect the positive DC conductor to circuit breaker 1.

Connect the negative conductor to the common terminal block adjacent to the circuit breaker on terminal block 1.

7.3 Testing Procedure

Note: Avlite recommends that all testing be done during the day.

1. Power the system on.
2. Check that no circuit breakers have tripped.
3. Check the function of all lights (i.e. CMI and all L-810(F) lights) during day and night mode by carrying out the following:
 - a. **-Night mode:** Cover the External Photocell and check night operation is functioning as expected. See note below.
 - b. **-Day mode:** Uncover the External Photocell and check day operation is functioning as expected. See note below.
4. Turn the Photocell Bypass Switch to the Night position and check night operation. See note below.
5. Turn the Photocell Bypass Switch back to the Day position and check day operation. See note below.
6. Turn the Photocell Bypass Switch back to the Auto position.
7. For O1 & O2 Variants only:
 - Trip the breaker for the CMI and ensure that the corresponding alarm is received (if monitoring is installed)
 - Trip the breaker for the L-810(F) lights and ensure that the corresponding alarm is received (if monitoring is installed)

Note:

In Night mode, all lights should be illuminated red and flashing in synchronization.

In Day mode, the CMI should be illuminated white and all L-810(F) fixtures should be off.



8.0 Maintenance and Servicing

Refer to the individual light manuals for light maintenance.

Ensure photocell is free from debris (i.e. snow, leaves, etc.) for reliable and continuous operation.

9.0 Replacement Parts

If replacement parts are required, please call a local Avlite distributor and reference the Product or Configuration Code called out in the “Product Configuration and Options” section of the corresponding product data sheet.

10.0 Troubleshooting

Problem	Possible Cause	Solution
CMI beacon is out (No Alarm)	No power to light	<ul style="list-style-type: none"> • Check for voltage in Control Box. • Check controller to Beacon cable connections at both ends.
	Junction box wiring	<ul style="list-style-type: none"> • Check junction box wiring.
CMI beacon is flashing white at night	Photocell input is high	<ul style="list-style-type: none"> • Check wiring. • Confirm there is 0 voltage at the Photocell input.
	Beacon in “limp mode”	<ul style="list-style-type: none"> • Visually confirm Beacon is flashing at ½ the intensity of normal day mode.
A single L-810(F) marker light is out (No Alarm)	Marker wiring	<ul style="list-style-type: none"> • Check the wiring of the malfunctioning lamp.
	Junction box wiring	<ul style="list-style-type: none"> • Check junction box wiring.
All marker L-810(F) lights out (No Alarm)	Junction box wiring	<ul style="list-style-type: none"> • Check junction box wiring.
	Cable to junction box	<ul style="list-style-type: none"> • Check controller to junction box cable connections at both ends. • Inspect cable for breaks.
Light is out	<ul style="list-style-type: none"> • No power to light • Light failure • Light in Alarm Mode 	<ul style="list-style-type: none"> • Physically check connections in junction boxes and control box. • If wiring functions properly, use an alternate power source to check the light. • Replace light if necessary.
CMI top light is not operational (no white or red mode)	<ul style="list-style-type: none"> • Wired incorrectly or wire(s) lose • Light failure • No power to the light 	<ul style="list-style-type: none"> • Check wiring of light in top junction box and Control Box. • Measure voltage at junction box. If correct input power, replace light. • If no voltage to the junction box, check output power from Control Box.



Problem	Possible Cause	Solution
L-810(F) middle light is not operational (others turning red at night or photocell covered)	<ul style="list-style-type: none"> • Wired incorrectly or wire(s) lose • Light failure 	<ul style="list-style-type: none"> • Check wiring to light in middle junction box • Measure voltage at junction box. If correct voltage replace light.
L-810(F) middle lights are not operational (top light red flashing at night or when photocell covered)	<ul style="list-style-type: none"> • Wired incorrectly or wire(s) lose • Light failure • No power to the light 	<ul style="list-style-type: none"> • Check wiring of lights in Middle junction box and Control Box. • Measure voltage at junction box. If correct input power, replace light. • If no voltage to the junction box, check output power from Control Box.
L-810(F) middle lights are not operational (top light red flashing during the day)	<ul style="list-style-type: none"> • Wired incorrectly or wire(s) lose • Photocell failure • PLC failure 	<ul style="list-style-type: none"> • Check wiring between Photocell and PLC, check wiring output of PLC. • Cover photocell. Check if output voltage of PLC changes. If no change, replace Photocell. • If Photocell operational, replace PLC.
All lights are not operational	<ul style="list-style-type: none"> • No or wrong input voltage • Tripped breaker or no output voltage • Wired incorrectly or lose wire(s) 	<ul style="list-style-type: none"> • Check input power to Control Box. • Check output voltage to both top and middle lights in the Control Box. • Check wiring between Control Box and top and middle junction boxes.
Light not transitioning between day-night or night-day	<ul style="list-style-type: none"> • Wired incorrectly or wire(s) lose • Photocell failure • PLC failure 	<ul style="list-style-type: none"> • Check wiring between Photocell and PLC, check wiring output of PLC. • Cover photocell. Check if output voltage of PLC changes. If no change, replace Photocell. • If Photocell operational, replace PLC.

Notes



Avlite Solution Verticals available



Airfield



Heliport



Obstruction



We believe technology improves navigation™

avlite.com info@avlite.com

Avlite Systems
Australia
+61 (0)3 5977 6128

Avlite USA LLC
USA
+1 (603) 737 1311

Avlite Asia Pte Ltd
Singapore
+65 6908 2917